



BV LCIE  
CHINA  
Number

N°1866AS12WTU30296

## ATTESTATION of conformity with European Directives

*Product:* **MCB**  
*Reference* **MC5 and MC3 Series**  
*Issued to* **WENZHOU TONGOU ELECTRICAL CO.,LTD.**  
*Address* **Paidong Industrial Zone, Qiligang, Yueqing City, Zhejiang province, China.**  
*Manufacturer* **WENZHOU TONGOU ELECTRICAL CO.,LTD.**  
*Technical characteristics* **Type B and C  
Ue=230V/400V, 240V/415V ~(1P); 400V, 415V ~(2P;3P;4P)  
In=6A;10A;16A;20A;25A;32A;40A;50A;63A  
Ics=Icn=4500A; Ui=500V; Uimp=4kV  
Energy limit class: 1  
Grid distance: 45mm; Screw diameter of load terminal =4,9mm**

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:

**Low Voltage Directive 2014/35/EU**

<i>Standards</i>	<i>Report number</i>	<i>Report date</i>
<b>EN 60898-1:2003 + A1:2004 + A11:2005 + A12:2008 + A13:2012</b>	<b>B180069</b>	<b>20/11/2018</b>

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product  
The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

**Shanghai (P.R. China), ), December 14<sup>th</sup>, 2018.**

**Charlie CHEN**  
**Product Line Manager**



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.  
Information given in this document, are related to the tested specimen of the described electrical sample.

**LCIE CHINA**  
必维欧亚电气技术咨询服务(上海)有限公司  
Version 3/2016.02.19

Building 4, No. 518, Xin Zhuan Road,  
CaoHejing Songjiang High-Tech Park,  
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000  
Fax: +86 21 6195 7001  
Email: [contact@cn.bureauveritas.com](mailto:contact@cn.bureauveritas.com)