



ATTESTATION of conformity with European Directives

Product: RCCB
Reference: TORD Series
Issued to: WENZHOU TONGOU ELECTRICAL CO.,LTD

Address: Paidong Industrial Zone,Qiligang,Yueqing City,Zhejiang province,China.

Manufacturer: WENZHOU TONGOU ELECTRICAL CO.,LTD
 1P+N and 3P+N(Neutral on left)
 110-240V/220V/230V/240V~(1P+N);380/400/415V~(3P+N)
 Type AC and A
 In=16A;20A;25A;32A;40A;50A;63A
 Inc=IΔc=3000A
 Im=IΔm=500A (16A;20A;25A;32A;40A;50A) and 10In (63A)

Technical characteristics: IΔn=30mA;100mA;300mA
 IΔno =15mA;50mA;150mA
 Grid distance = 45 mm
 Ui= 415V
 Uimp=4kV
 Material group=IIIa
 Screw diameter=5,8mm
 50/60Hz

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

Standards	Report number	Report date
EN 61008-1:2012+A1:2014+A2:2014+A11:2015 EN 61008-2-1:1994+A11:1998	B220106	08/10/2022

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product
The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

Shanghai (P.R. China), November 7th, 2022.

Charlie CHEN
Product Line Manager



be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA

必维欧亚电气技术咨询服务(上海)有限公司

Building 4, No. 518, Xin Zhuan Road,
CaoHejing Songjiang High-Tech Park,
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000
Fax: +86 21 6195 7001
Email:contact@cn.bureauveritas.com