



A P P R O V A L S[®]

Certificate of Suitability

Certificate No.: SAA192260

Certificate Holder: Wenzhou Tongou Electrical Co., Ltd
Paidong Industrial, Liushi Town,
Wenzhou City,
P.R. China

Class Description: Non-Prescribed
Product Description: RCCB (Type B)
Trade Name: TONGOU
Model No.: TORD6B-63
Markings: Un: 230/240Vac (1P+N), 400/415Vac (3P+N), 50/60Hz
In: 63A Type B
I Δ n: 30mA, 100mA, 300mA Type A
Icn: 10kA
I Δ m: 1000A

Standard: IEC 62423:2009
AS/NZS 61008.1:2015

Conditions: Nil

Certification Mark: RCM and SAA192260

Date First Registered: 26 August 2019
Date of Expiry: 26 August 2024

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 26-08-19 192260/1



A P P R O V A L S ®

Certificate of Suitability

Addendum

Certificate No.: SAA192260

Date of Issue: 26 August 2019

Class Description: Non-Prescribed
Product Description: RCCB (Type B)

Additional Models	Trade Name	Rating
TORD6B-40	TONGOU	Un: 230/240Vac (1P+N), 400/415Vac (3P+N), 50/60Hz In: 40A Type B IΔn: 30mA, 100mA, 300mA Type A Icn: 10kA IΔm: 1000A
TORD6B-32	TONGOU	Un: 230/240Vac (1P+N), 400/415Vac (3P+N), 50/60Hz In: 32A Type B IΔn: 30mA, 100mA, 300mA Type A Icn: 10kA IΔm: 1000A
TORD6B-25	TONGOU	Un: 230/240Vac (1P+N), 400/415Vac (3P+N), 50/60Hz In: 25A Type B IΔn: 30mA, 100mA, 300mA Type A Icn: 10kA IΔm: 1000A
TORD6B-16	TONGOU	Un: 230/240Vac (1P+N), 400/415Vac (3P+N), 50/60Hz In: 16A Type B IΔn: 30mA, 100mA, 300mA Type A Icn: 10kA IΔm: 1000A

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 26-08-19 192260/2



26 August 2019

Wenzhou Tongou Electrical Co., Ltd
Paidong Industrial, Liushi Town,
Wenzhou City,
P.R. China

C/- Intertek Testing Services Ltd - Shanghai

Dear Sir

**Certificate of Suitability – SAA192260
RCCB (Type B)
Model No.: TORD6B-63**

We are pleased to advise that your application for certification of the above electrical product has been successful.

Please ensure that you keep the enclosed Certificate in a safe place as it is your evidence that the product has been certified.

The certified product must now be marked with the Regulatory Compliance Mark (RCM) and may also be marked with the SAA Number SAA192260. The RCM must be used in accordance with the conditions set out in the relevant parts of AS/NZS 4417.

Please note that if the electrical product is modified in any way or your company details change you are required to notify this office of the details of the modification. You can either download the required form from our web page or contact our office.

As part of our operational guidelines we are required to check that a certified product remains compliant during the term of the Certificate. At some stage during this term we may request a sample for evaluation.

If you need any further information or need to discuss this letter please don't hesitate to contact our office.

Yours sincerely

A handwritten signature in black ink, appearing to be 'K' or similar, written over a white rectangular area.

**For and on behalf of
SAA Approvals Pty Ltd**

ABN 91 125 451 327

P. +61 7 3393 9455

F. +61 7 3393 9499

E. info@saaapprovals.com.au

W. www.saaapprovals.com.au

PO Box 189, Cannon Hill QLD 4170
5/20 Rivergate Place, Murarrie QLD 4172