BV LCIE CHINA Number

## 

## **ATTESTATION** of conformity with European Directives

Product:	МССВ
Reference	TOS1-125 Series
Issued to	WENZHOU TONGOU ELECTRICAL CO.,LTD
Address	Paidong Industrial Zone,Qiligang,Yueqing City,Zhejiang province,China.
Manufacturer	WENZHOU TONGOU ELECTRICAL CO.,LTD
Technical characteristics	Ue: 400V~
	Utilization category: A
	Ie:16A;20A;25A;32A;40A;50A;63A;80A;100A;125A
	50/60Hz
	Icu=35kA
	Ics=22kA
	Ui= 690V
	Uimp=6kV
	IP40 for front cover
	Pollution degree: 3
	<b>Reference temperature: 40°C</b>
	Distance for metal screen:
	Back:0mm Front:0mm; Top:50mm Botton:50mm; Left:0mm
	Right:0mm(values declared by client)

The submitted sample of the above equipment has been tested for **C C** marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

Standards	Report number	Report date
EN 60947-2:2017+A1:2020; EN 60947-1:2007 + A1:2011 + A2:2014	B200080	2020-11-23

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product The CE marking may be affixed if all relevant and effective European Directives with CE are applicable

Shanghai (P.R. China), December 9th, 2020.



Charlie CHEN Product Line Manager

be reproduced, except in full, without the written approval of BV LCIE China. Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA 必维欧亚电气技术咨询服务(上海)有 限公司 Version 3/2016.02.19

Building 4, No. 518, Xin Zhuan Road, CaoHejing Songjiang High-Tech Park, Shanghai P.R.C (201612) Tel: +86 21 6195 7000 Fax: +86 21 6195 7001 Email:<u>contact@cn.bureauveritas.com</u>